

Flange

Molded-In Reinforcing Ring

Flange Stops

Fabric Reinforcement with

Multi-Layered

Kevlar® Tire Cord

#### **SAFEFLEX SFEJ** Dimensions and Allowable Movements

Pip	e (in)	Pipe	(mm)	Allowable Movements								
Size (in)	Length (in)	Size Length (mm) (mm)		Angular (degrees)	Comp (in)	Compression (in) (mm)		Elongation (in) (mm)		Transverse $\frac{1}{2}$ (in) $\frac{1}{2}$ (mm)		
11/2 2 21/2 3 4 5	2 <sup>2</sup> 4	40 50 65 75 100 125	100	21 20 19 18 17 16	5/8	16	1/2	12	3/8	9.5		
6 8 10 12	6	150 200 250 300	150	15 14 13 12	1	25	5/8	16	5/8	16		
14 16 18 20	9	350 400 450 500	225	10 9 8 7	11/8	29	7/8	22	7/8	22		
24	10	600	250	6	11/8	29	1	25	1	25		

### **SAFEFLEX SFDEJ** Dimensions and Allowable Movements

Pipe (in) Pipe (mm)			(mm)	Allowable Movements								
Size L (in)	ength	Size (mm)	Length (mm)	Angular (degrees)	Comp (in)	ression (mm)	Elon (in)	gation (mm)		sverse <u>†</u> (mm)		
11/2 2 21/2 3 4 5 6	7	40 50 65 75 100 125 150	175	36 34 32 30 28 24 22	11/4	32	3/4	19	3/4	19		
8 10 12	8	200 250 300	200	20 18 16	11/2	38	7/8	22	7/8	22		
14	10	350	250	14	15/8	41	1	25	1	25		

#### **SAFEFLEX SFU** Dimensions and Allowable Movements

Pipe (in)	Pipe (mm)	Allowable Movements								
Size Length (in) (in)	Size Length (mm) (mm)	Angular (degrees)	Compression (in) (mm)	Elongation Transver	Transverse + (in) + (mm)					
3/4 7 1 7 11/4 8 11/2 8 2 8	20 175 25 175 32 200 40 200 50 200	25 24 23 22 21	3/4 19	3/8 10 3/8 1	0					

### **FITTING OPTIONS**

**SAFEFLEX** SFU-DI

Ductile Iron Threaded End



Split Baked Enamel

Ductile Iron

Floating

Flanges

SFU-SS Stainless Steel Threaded End











# **SFU-BT** Brass Threaded End


## SAFEFLEX SFEJ, SFDEJ, SFDCR and SFU KEVLAR® REINFORCEMENT

Standard and High Pressure Construction-Pressure Reduction at Higher Temperatures												
Construction Types & Sizes (in) (mm)				In PSI 2					ı In Bar 110°C		Max. \ in Hg	/acuum Minus Bar
SFEJ Standard 11/2" - 16" 40mm - 600mm	250	245	235	225	215	17	16.5	16	15	14	18"	0.6
SFEJ Standard 18" - 24" 450mm - 600mm	180	175	170	165	155	12	11.5	11	10.5	10	18"	0.6
SFDEJ Standard 11/2" - 14" 40mm - 350mm	250	245	235	225	215	17	16.5	16	15	14	14"	0.5
SFDCR Standard All Sizes	250	245	235	225	215	17	16.5	16	15	14	14"	0.5
SFU Standard All Sizes	250	245	235	225	215	17	16.5	16	15	14	18"	0.6
SFEJ High Pressure 11/2" - 16" 40mm - 400mm	335	325	315	300	285	23	22	21	20	19	29"	1.0
SFEJ High Pressure 18" - 24" 450mm - 600mm	225	220	210	200	190	15	14.5	14	13.5	13	29"	1.0
SFDEJ High Pressure 11/2" - 14" 40mm - 350mm	335	325	315	300	285	23	22	21	20	19	22"	0.7

Burst pressures are a minimum of three times Operating Pressures.









Rods with oversized washers &




**MASON CR** CONTROL RODS

**ACC CONTROL** CABLES


Connectors installed in piping systems that are anchored on both sides of the connectors need no control rods or cables. Piping movements must be within the tabulated allowables.


Connectors installed on unanchored piping or connected to isolated equipment require control rods or cables for pressures as tabulated.



Type CR and ACC control rods and cables are very different than the average rod and rubber washer arrangement. Our sets are all made with oversized washers on the ends to limit the maximum loading on the rubber materials to 1000psi (70kg/cm²). Competitive systems use 1/4" (6mm) rubber washers that are the same size as the small standard washers. Thrust forces are so high that standard washers extrude out. In addition to the increased area and thickness of the rubber materials, all our control rod washers are molded with rubber bushings so the rod or cable cannot contact the steel restraining plates and short circuit the system acoustically.


### Installation Instructions for Safeflex SFEJ & SFDEJ Install only where leakage or failure will not result in injury or property damage.





SFEJ AND SFDEJ **CONNECTORS** THAT ARE USED IN EXPANSION **APPLICATIONS** MUST BE INSTALLED WITH ANCHORS ON EITHER SIDE OF THE CONNECTOR.


SFEJ AND SFDEJ CONNECTORS USED AS NOISE AND VIBRATION DAMPENERS ONLY AND INSTALLED IN UNAN-CHORED PIPING WILL GROW IN RESPONSE TO THE PRESSURE AS SHOWN BELOW. Adjust the spring mountings so the equipment is at the proper level. Leave a space between pipe flanges equal to the length shown below and draw the connectors out evenly with the flange bolts. Spring supported equipment may lift in response to the tightening so the connector may not be fully extended. When the connector is at operating pressure the system will return to the original position.




**VARIOUS PRESSURES SAFEFLEX SFEJ** Pressure Extension Table

Pipe Size (in)	0 psi	100 psi	Constructi 200 psi ace Length	250 psi	Pipe Size	0 Bar	Bar Co 6.8 Bar to Face	13.6 Bar	17 Bar
11/2 2 21/2 3 4 5 6 8 10 12 14 16	4 4 4 4 4 6 6 6 6 9 9	4 4 4 4 41/4 61/4 61/4 63/8 91/4 91/2	4 4 4 4 43/8 43/8 63/8 63/8 63/8 61/2 93/8 93/4	4 4 4 4 43/8 43/8 63/8 63/8 63/8 61/2 91/2 97/8	40 50 60 75 100 125 150 200 250 300 350 400	100 100 100 100 100 100 150 150 150 225 225	100 100 100 100 106 106 156 156 156 160 231 238	100 100 100 100 110 110 160 160 163 235 244	100 100 100 100 110 110 110 160 160 163 238 247
Pipe Size (in)	180 lb. Construction 0 100 150 180 psi psi psi psi Face to Face Length (in)				Pipe Size (mm)	0 Bar			
18 20 24	9 9 10	95/8 95/8 10 <sup>5</sup> /8	93/4 93/4 107/8	97/8 97/8 11	450 500 600	225 225 250	241 241 266	244 244 269	247 247 275

CAUTION: This extension procedure is an ABSOLUTE must on all connections to spring mounted systems such as pumps (when control rods are not used) or the connections may drive the spring solid under the pumps or shift the foundation.




Pipe Size	0 psi	250 lb. 0 100 psi	Construction 200 psi	on 250 psi	Pipe Size	17 0 Bar	Bar Co 6.8 Bar	nstruct 13.6 Bar	ion 17 Bar
(in)		Face to Fa	ace Length	(in)	(mm)	Face to Face Length (mm)			
11/2	7	7	7	7	40	175	175	175	175
2	7	7	7	7	50	175	175	175	175
21/2	7	7	7	7	60	175	175	175	175
3	7	71/8	73/16	71/4	75	175	178	180	181
4	7	71/8	73/16	71/4	100	175	178	180	181
5	7	71/8	71/4	73/8	125	175	178	181	185
6	7	73/16	73/8	71/2	150	175	180	185	188
8	8	83/16	83/8	81/2	200	200	205	210	213
10	8	81/4	81/2	85/8	250	200	206	213	216
12	8	81/4	81/2	85/8	300	200	206	213	216
14	10	101/4	101/2	105/8	350	250	256	263	256



Use Control Rods or Cables only if:

- 1. Expansion Joints cannot be preextended.
- 2. Pipe movement is no problem.
- 3. As an added precaution.

All high pressure connectors should have control rods set at maximum expansion joint elongation.



All flanged expansion joints illustrated in this bulletin are available with:

- 150 lb ASA Drilling
- 300 lb ASA Drilling
- BRITISH Series E Drilling
- BRITISH Series F Drilling

Liner and Cord Frictioning

## DIN or PIN-10

- DIN or PIN-16
- DIN or PIN-25

#### SAFEFLEX SFDCR Dimensions and Allowable Movements

Pipe (	Pipe (in) Pipe (mm)			Allowable Movements								
Size Length (in) (in)		Size (mm)	Length (mm)	Angular (degrees)	Compression (in) (mm)		Elor (in)	ngation (mm)				
3x2 3x21/2	6 6	75x50 75x60	150 150	25	1	25	5/8	16	5/8	16		
4x3 5x4	7 8	100x75 125x100	175 200	20	11/4	32	3/4	19	3/4	19		
6x4 6x5 8x6 10x8	9 9 11 12	150x100 150x125 200x150 250x200	225 225 275 300	15	15/8	41	3/4	19	7/8	22		

### SAFEFLEX SFDCR

Pressure Extension Table 250 lb 17 Bar Construction

Pipe Size (in)	0 psi	100 psi	200 psi Face Len	250 psi	Pipe Size (mm)	0 Bar	6.8 Bar ce to Fa	13.6 Bar	17 Bar
				<u> </u>		i at		LCC LCI	igiii
3x2	6	61/8	63/16	61/4	75x50	150	153	155	156
3x21/2	6	61/8	63/16	61/4	75x60	150	153	155	156
4x3	7	71/8	71/4	73/8	100x75	175	178	181	185
5x4	8	83/16	83/8	81/2	125x100	200	205	210	212
6x4	9	93/16	93/8	91/2	150x100	225	230	235	237
6x5	9	91/4	97/16	99/16	150x125	225	231	236	239
8x6	11	113/8	111/2	115/8	200x150	275	285	287	291
10x8	12	121/2	123/4	13	250x200	300	312	319	325

### Installation Procedures for Safeflex SFEJ, SFDEJ, SFDCR and SFU

It is our general recommendation that flexible connectors are always installed on the equipment side of the shut-off valve, and they are not used in pipe lines that pass through finished ceilings where water damage to the structure or the equipment below can be extensive.

### Install only where leakage or failure will not result in injury or property damage.

- 1. a. Expansion joint rubber flanges must be in contact with a flat surface. Normal 1/16" raised face is o.k. Unacceptable depressions or protrusions are typical of victaulic or similar flanges.
  - b. Flange stops must bear on full diameter mating flanges.
  - c. Rubber flanges will not retain loose elements in valve bodies that rely on contact with a steel flange. For example, some check valves are manufactured with brass inserts positioned by screws. When mating steel flanges with these valves, there is no problem. However, with a rubber connector, it cuts the rubber face and can cause failure, leakage or brass insert escape.
- 2. Any of the above conditions must be corrected by installing a minimum 1/2" thick full diameter steel flange drilled to standard dimensions so the flange bolts pass through it. The I.D. matches the O.D. of the piping. Gasket between this filler flange and the mating steel flange.
- Before installing the connector be certain that all surfaces are clean and there are no sharp edges of any kind on the steel flanges. No gasket is required. Apply a thin film of graphite dispersed in glycerin or water to the face of the rubber flanges before installing. No other type of lubricant or seal should be used on the flange face. The graphite prevents the rubber from adhering to the metal flange so that the rubber joint can be removed without damage, should it ever be necessary.
- If the connector is to be installed in a system where the operating pressures do not dictate the use of control rods, but the connector is to be pre-extended to allow for growth under pressure, the gap between the piping flanges should be large enough to allow for the growth as indicated on the operating pressure chart.
- Expansion joints installed for expansion and compression applications should be installed at normal length. Check allowable movements against design requirements between anchors.
- 6. Check temperature and pressure ratings and never exceed them.
- 7. Check for chemical compatibility with the ordered material.
- Do not weld near the expansion joints or weld the steel flanges to the piping after the expansion joints are installed. This will either burn or seriously damage the expansion joints.

- 9. Although the expansion joints will readily adjust themselves to misaligned flanges within the specified movements, they should not be installed where there is more than 1/8" of initial misalignment or lack of parallelism in the expansion joints.
- Slide the connector into position and insert all the flange bolts. The rubber face must be centered exactly on the opening. Be sure that the bolts are inserted with the heads facing the rubber and the nuts on the outside so they are on the outside of the mating flange. If it is impossible to insert the bolts in this direction, the tightened end of the bolt must not protrude more than 1/8" beyond the inside nut. Larger protrusions may result in the bolt cutting into the rubber cover.
- After all bolts are inserted, make them finger tight and then proceed to adjust them evenly in a circle. Tighten the bolts to 60% of the maximum recommended torque for the bolt size until all bolts have the same tightness. Tightness may be increased if there is joint leakage.
- All rubber materials tend to relax over a period of time. It is good practice to check the tightness of the bolts for the 60% torque about two weeks after installation, and in extreme cases, particularly when a line is heated up and allowed to cool repeatedly it is advisable to continue to check bolt tightness on a monthly basis until such time as the last check shows no further tightening is required.
- 13. Allowing the bolts to loosen may cause leaks.
- Insulation on cold lines should be installed for easy removal to facilitate retightening.
- In order to prevent heat buildup, expansion joints in hot lines should not be insulated.
- While our expansion joints are guaranteed for a period of one year and designed for many years of service, it is suggested that expansion joints are replaced every five years. Cover cracking is of no significance and only cosmetic.

#### SFU Installation Instructions (See general precautions above)

- 1. Attach flanges to piping so length between inside flange faces is equal to face to face length of rubber section of the SFU.
- Insert center section of the SFU and the 3 bolts on each end. Tighten evenly to 60% of torque value.
- 3. Retighten as in 12 above

IT IS IMPORTANT TO FOLLOW ALL OF THE NUMBERED INSTRUCTIONS TO AVOID NEEDLESS PROBLEMS.



### MASON INDUSTRIES.Inc.

350 Rabro Drive, Hauppauge, NY 11788 • Reply to:PO Box 410, Smithtown, NY 11787 631/348-0282 • FAX 631/348-0279 • Web: www.mason-ind.com • E-mail: Info@Mason-ind.com